



PROPOSAL

Issue:

One of the pumps at the CR 500 W lift station has recently stopped working. These pumps are necessary to transport wastewater from around the community to the Wastewater Treatment Plant.

Proposal:

Given the age of the pump, the cost to buy replacement parts would surpass the price of a new pump. George Kane, WWTP Superintendent, believes it is in the town's best interest to opt for an entirely new pump which is also has a higher efficiency motor than the currently broken pump. BBC Pump & Equipment has provided the following quote.

Cost:

\$13,760.50

Cost to be paid from WWTP Machinery & Equipment 6201001444